



**BUREAU
VERITAS**

Certificate for the NS protection

Manufacturer / applicant: SOLARMAX GmbH
Zur Schönhalde 10
89352 Ellzee
Germany

| | |
|------------------------------------|--|
| Type of grid and plant protection: | Integrated NS protection |
| Assigned to generation unit type: | MAX.STORAGE 6, MAX.STORAGE 8, MAX.STORAGE 10, MAX.STORAGE 12, MAX.STORAGE 15 |

Firmware version: 3.3.0 or higher

Connection rule: VDE-AR-N 4105:2018-11 – Power generation systems connected to the low-voltage distribution network
Technical minimum requirements for the connection to and parallel operation with low-voltage distribution networks.

Applicable standards / directives: DIN VDE V 0124-100 (VDE V 0124-100):2020-06 – Grid integration of power generation systems – low voltage
Test requirements for power generation units to be connected and operated parallel with the low-voltage distribution networks

The above mentioned grid and plant protection has been tested and certified according to the test guideline VDE 0124-100. The electrical properties required in the connection rule are satisfied.

- Setting values and disconnect times
- Properly functioning functional chain "NS protection – interface switch"
- Technical requirements of the switching device
- Integrated interface switch that can also be used in conjunction with a central interface protection relay (VDE-AR-N 4105:2018-11 §6.4.1)
- Active detection of unintended islanding
- Single-fault tolerance

The certificate contains the following information:

- Technical specifications of the NS protection and corresponding power generation types
- Setting values of the protection functions
- Trip values of the protection functions

Report number: 20TH0512-VDE0124-100:2020_0

Certificate number: U21-0290

Certification program: NSOP-0032-DEU-ZE-V01

Date of issue: 2021-03-31

Certification body



Thomas Lammel



Certification body of Bureau Veritas Consumer Products Services Germany GmbH Accredited according to DIN EN ISO/IEC 17065

A partial representation of the certificate requires the written permission of Bureau Veritas Consumer Products Services Germany GmbH

E.6 and E.7 Requirements for the test report for the NS protection

Extract from test report for NS protection
 "Determination of electrical properties"

Nr. 20TH0512-VDE0124-100:2020_0

NS protection as integrated NS protection

| | |
|---|--|
| Manufacturer / applicant: | SOLARMAX GmbH Zur Schönhalde 10 89352 Ellzee Germany |
| Type of grid and plant protection: | integrated NS protection |
| Assigned to generation unit type: | MAX.STORAGE 6, MAX.STORAGE 8, MAX.STORAGE 10, MAX.STORAGE 12, MAX.STORAGE 15 |
| Firmware version: | 3.3.0 or higher |
| Integrated interface switch: | Type of switching equipment 1: Relay Type of switching equipment 2: Relay |
| Measurement period: | 2021-01-23 to 2021-03-18 |

Inverter

| Protection function | Setting value | Trip value | Disconnection time ^a |
|----------------------------------|---------------|------------|---------------------------------|
| Voltage drop protection U < | 184,0 V | 185,5 V | 3,037 s |
| Voltage drop protection U << | 103,5 V | 103,1 V | 0,321 s |
| Rise-in-voltage protection U> | 253,0 V | -- | 474 s ^b |
| Rise-in-voltage protection U>> | 287,5 V | 287,2 V | 0,134 s |
| Frequency decrease protection f< | 47,50 Hz | 47,49 Hz | 0,116 s |
| Frequency increase protection f> | 51,50 Hz | 51,50 Hz | 0,144 s |

^a proper time of interface switch 20 ms

^b longest disconnection of the rise-in-voltage protection as a moving 10-minute-average, tested according clause 5.5.7 Protection devices and protection settings of VDE 0124-100

The disconnect time (sum of trip time of grid and plant protection and delay time of interface switch) must not exceed 200 ms.

A check of the overall functional chain "NS protection – interface switch" resulted in a successful disconnection.

The above mentioned grid and plant protection with the assigned power generation units has met the requirements for islanding detection with the help of the active method (resonant circuit test).

The above-mentioned NS protection meet the requirements for synchronization.